



ANNUAL REPORT

Drinking-Water System Number:	260034372
Drinking-Water System Name:	Ansnorveldt
Drinking-Water System Owner:	Township of King
Drinking-Water System Category:	Small Municipal Residential
Period being reported:	January 1, 2022 to December 31, 2022

**Complete if your Category is Large Municipal Residential or Small Municipal Residential**

Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [X]

Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Township of King  
2585 King Road  
King City, ON L7B 1A1  
www.king.ca

**Complete for all other Categories.**

Number of Designated Facilities served:

0

Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]

Number of Interested Authorities you report to:

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [ ] No [X] NA

Indicate how you notified system users that your annual report is available, and is free of charge.

[X] Public access/notice via the web



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

- ☒ Public access/notice via Government Office  
☐ Public access/notice via a newspaper  
☐ Public access/notice via Public Request  
☐ Public access/notice via a Public Library  
☒ Public access/notice via other method: Report to Council

## Describe your Drinking-Water System

Distribution System Class 1  
 Receives all treated water from Region of York water treatment plant and groundwater wells.  
 Secondary disinfection is provided through the maintenance of chlorine residual.

## List all water treatment chemicals used over this reporting period

Refer to York Region Annual Report for the Ansnorveldt Water Supply System.

## Were any significant expenses incurred to?

- ☐ Install required equipment  
☐ Repair required equipment  
☐ Replace required equipment

## Please provide a brief description and a breakdown of monetary expenses incurred

N/A

Provide details on the notices submitted in accordance with subsection 18(1) of the  
 Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported  
 to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
July 11, 2022	Total Coliform	Present	Present/ Absent	Re-sampled up-stream, down-stream and at adverse location.	July 12, 2022
July 14, 2022	Total Coliform	Present	Present/ Absent	Re-sampled up-stream, down-stream and at adverse location.	July 14, 2022
July 15, 2022	Total Coliform	Present	Present/ Absent	Flushed mains, cleaned sample station, four consecutive sets of re-sample up-stream, down-stream and at	July 15 – July 22, 2022



				adverse location were taken and all four sets came back with no presence of TC.	
--	--	--	--	---	--

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	N/A				
Treated	N/A				
Distribution	107	Absent	Absent – Present	101	0-56

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report**

	Number of Grab Samples	Range of Results (min #)-(max #)
Chlorine	225	0.15-2.12
Fluoride (If the DWS provides fluoridation)	N/A	

*NOTE: For continuous monitors use 8760 as the number of samples.*

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument:**

Not Applicable

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results. Township values reflect the latest sample. Refer to York Region's Annual Report, available on their website, for complete test results.**



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
*Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite	Nov. 21, 2022	<0.05	mg/L	No
Nitrate	Nov. 21, 2022	<0.50	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

## Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Results - mg/L (min#) – (max #)	Number of Exceedances
Plumbing		N/A	
Distribution Alkalinity	2	166	0
Distribution Lead	2	0.0005	0

**Note that all four of the Township Drinking Water Systems are subject to the “exemption” protocols**

Summary of Organic parameters sampled during this reporting period or the most recent sample results. **Township values an average of the sample results for the Report year. Refer to York Region’s Annual Report, available on their website, for complete test results.**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				



Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Haloacetic Acid (HAA)	Feb.28/22 May.30/22 Sep.06/22 Nov.21/22	11.00	µg/L	None
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				



<b>THM</b> (NOTE: show latest annual average)	Feb.28/22 May.30/22 Sep.06/22 Nov.21/22	60.95	µg/L	None
<b>Temephos</b>				
<b>Terbufos</b>				
<b>Tetrachloroethylene</b>				
<b>2,3,4,6-Tetrachlorophenol</b>				
<b>Triallate</b>				
<b>Trichloroethylene</b>				
<b>2,4,6-Trichlorophenol</b>				
<b>2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)</b>				
<b>Trifluralin</b>				
<b>Vinyl Chloride</b>				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards

Parameter	Result Value	Unit of Measure	Date of Sample
THM	60.95	µg/L	Running Average